




Introduction to the Hawaiian Electric Companies



DER Interconnection Programs

- Legacy Program: net energy metering (NEM)
 - Full retail rate
 - closed, 400 MW installed
- 2) Replacement programs
 - CGS (customer grid supply), reduced incentive, closing soon, 25 MW cap
 - CSS (customer self supply) no export allowed
- 3) 2018 DER Phase II (req. advanced inverters)
 - Smart export (constrained export hours, non-solar hours) 25 MW cap, PV+ES
 - CGS+, PV only, 35 MW, reduced incentive for export, utility curtailment control



Legacy Demand Response on the Hawaiian Islands

EnergyScout Program



Utility sends an

alert via a 3rd

party paging

service





service/Eaton

Cooper Yukon

3rd party

paging





One-way paging **Load Control** Receiver receives the alert



carries out the predetermined directives



Small & Medium Business 200 customers 1 MW (dispatch + UFLS)

Residential (2004) 30,000 customers 8 MW (dispatch + UFLS)

Fast DR (10 min reserve)













Facility's EMS



Utility sends an alert via Internet

3rd party OpenADR 2.0b VTN







Integrated Demand Response Program Portfolio PUC established objectives to expand the Companies DR programs (2014):

- Integrated portfolio of programs
 - Deals with variable generation variability
 - Provides system reliability
 - Delivers ancillary services
 - Ensures customer benefits
- Comprehensive evaluation
 - Evaluation of DR potential
 - Valuation of services
- Third-party participation, e.g. aggregators

January 2018: PUC approves Companies' portfolio – Customer recruitment for deployment of DR resources for Oahu (and to a smaller extent, Maui and Hawai'i) to start by third-quarter 2018

November 2018: PUC approves DRMS Project



Grid Services and Grid Service Tariffs

Capacity

- Load shift program (shift load to the mid-day from evening peak)
- Time of use rates
- Peak reduction program

Fast Frequency Response (FFR)

 Autonomously triggered (load reduction or generation increase) for 30 min or until frequency stabilizes, due to an under frequency excursion: 59.7MHz, 12 cycle response

Regulating Reserve (secondary frequency regulation)

Response to a frequency regulation signal (AGC: automatic generation control)

Replacement Reserve

10-30 minute response after notification, 1-2 hour duration



Questions to Answer

- 1. What is your utility's policy towards using standard communications protocols? Why is it that way? Is it evolving and how?
- 2. Do you mandate the use of OpenADR? If yes, for what applications and why? If not, why not?
- 3. If you require the use of OpenADR, do you require certified products? Why or why not?
- 4. What would be most valuable to your utility from the OpenADR Alliance over the next 2-3 years? Value can be technical, policy, education or?





Thank you

