


Prüfbericht-Nr.: Test Report No.:	60362718 001	Auftrags-Nr.: Order No.:	150224608	Seite 1 von of 17 Page 1 von of 17
Kunden Referenz-Nr.: Client Reference No.:	N/A	Auftragsdatum: Order date:	2020-04-13	
Auftraggeber: Client:	Sumitomo Electric Industries, Ltd. 1-1-3, Shimaya, Konohana-ku, Osaka, Japan			
Gegenstand der Prüfung: Test item:	SEI-VEN 2.0b			
Bezeichnung / Typ-Nr.: Identification / Type No.:	2.0			
Auftrags-Inhalt: Order content:	OpenADR Certification Test			
Prüfgrundlage: Test specification:	OpenADR 2.0b Certification Test Specification Version 1.1.4 OpenADR 2.0a Certification Test Specification Version 1.1.3			
Wareneingangsdatum: Date of receipt:	N/A			
Prüfmuster-Nr.: Test sample No.:	N/A			
Prüfzeitraum: Testing period:	2020-06-22 ~ 2020-06-24			
Ort der Prüfung: Place of testing:	TÜV Rheinland Japan Ltd. 3-19-5 Shin-Yokohama, Kouhoku-ku Yokohama 222-0033, Japan			
Prüflaboratorium: Testing laboratory:	TÜV Rheinland Japan Ltd.			
Prüfergebnis: Test results:	The test item passed the test specification(s).			
Geprüft von Tested by:	Kontrolliert von Reviewed by:			
2020-06-30	Atsuhiko Endo	2020-06-30	Tam Tran Thanh	
Datum Date	Name / Stellung Name / Position	Unterschrift Signature	Datum Date	Name / Stellung Name / Position
				Unterschrift Signature
Sonstiges / Other Aspects:				
Zustand des Prüfgegenstandes bei Anlieferung: Condition of the test item at delivery:		Prüfmuster vollständig und unbeschädigt Test item complete and undamaged		
<p>*Legende: 1 = sehr gut 2 = gut 3 = befriedigend 4 = ausreichend 5 = mangelhaft P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet Legend: 1 = very good 2 = good 3 = satisfactory 4 = sufficient 5 = poor P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested</p>				
<p>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark</p>				

Contents

1	General Product Information	3
1.1	Client Information	3
1.2	General SUT Information.....	3
1.3	General EUT Description.....	3
1.4	Profile	3
2	Testing Laboratory.....	4
2.1	Test Equipment	4
2.2	Test Setup.....	4
3	Information about Test Results	5
3.1	General	5
4	Test Results	6
4.1	Profile 2.0b.....	6
4.1.1	VEN Pull Tests	6
4.1.1.1	EiRegisterParty Service	6
4.1.1.2	EiOpt Service.....	6
4.1.1.3	EiReport Service	7
4.1.1.4	EiEvent Service	7
4.1.1.5	EiEvent Ported A Profile	8
4.1.1.6	General Tests	9
4.1.2	VEN Push Tests.....	10
4.1.2.1	EiRegisterParty Service	10
4.1.2.2	EiOpt Service.....	10
4.1.2.3	EiReport Service	11
4.1.2.4	EiEvent Service.....	11
4.1.2.5	EiEvent Ported A Profile	12
4.1.2.6	General Tests	13
4.1.2.7	XMPP Tests	13
4.2	Profile 2.0a	14
4.2.1	VTN Pull Tests	14
4.2.1.1	Application Layer Test Cases.....	14
4.2.1.2	Security Test Cases.....	14
4.2.2	VTN Push Tests.....	15
4.2.2.1	Application Layer Test Cases.....	15
4.2.2.2	Security Test Cases.....	15
4.2.3	Transport Tests	15
5	Remarks and References	16
6	Photos	17

1 General Product Information

1.1 Client Information

Company Name: see page 1
Address: see page 1
Contact Person: Miyoshi Hidekazu, Jumpei Tamura
Phone: +81-3-6466-8231
E-mail: miyoshi-hidekazu@sei.co.jp, tamura-jumpei@sei.co.jp

1.2 General SUT Information

The system under test is software implementation of OpenADR protocol installed on Cloud.

Serial Number: N/A
Hardware Version: N/A
Firmware version: 2.0.0

1.3 General EUT Description

Equipment under test: see page 1

1.4 Profile

Product type: VTN
OpenADR profile: 2.0b, 2.0a
Mode: Pull, Push
Transport: Simple HTTP, XMPP
Security: Standard Security

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.:

150224608

Seite 4 von of 17
Page 4 von of 17

2 Testing Laboratory


Company name: TÜV Rheinland Japan Ltd.
Address: see page 1

2.1 Test Equipment

Equipment ID	Model Product name	Manufacture	Category	Version
1800528	OpenADR Test Harness for 2.0b	QualityLogic	Software	1.1.4
1800440	OpenADR Test Harness for 2.0a	QualityLogic	Software	1.1.3

*A patch file is applied to the test case A_E2_0525_TH_VEN_1 / E2_0525_TH_VEN.
See "5 Remarks and References"

2.2 Test Setup



3 Information about Test Results

3.1 General

Documentation of tested devices and results:

The complete set of measurement results is stored at the TÜV Rheinland Japan Ltd. test laboratory and is available on demand.

Interpretation of test results:

The results of the inspection are described on the following pages. "Pass" in the test result list of this test report means the performed test according to the test specification was verified and that the tested device is conformant to the specification. "Fail" means that the performed test according to the test specification was verified and the tested device is not conformant to the specification or that test didn't run to completion because the tested device is not conformant to the specification. "N/A" means the test cases are optional and/or not applicable to the tested device.

4 Test Results

4.1 Profile 2.0b

4.1.1 VTN Pull Tests

4.1.1.1 EiRegisterParty Service

No.	Test Case Name	Date	Result
01	N1_0010_TH_VEN	Jun 22 2020	PASS
02	N1_0015_TH_VEN	Jun 22 2020	PASS
03	N1_0020_TH_VEN	Jun 22 2020	PASS
04	N1_0025_TH_VEN	Jun 22 2020	PASS
05	N1_0030_TH_VEN	Jun 22 2020	PASS
06	N1_0040_TH_VEN	Jun 22 2020	PASS
07	N1_0050_TH_VEN	Jun 22 2020	PASS
08	N1_0060_TH_VEN	Jun 22 2020	PASS
09	N1_0065_TH_VEN	Jun 22 2020	PASS
10	N1_0070_TH_VEN	Jun 22 2020	PASS
11	N1_0080_TH_VEN	Jun 22 2020	PASS

4.1.1.2 EiOpt Service

No.	Test Case Name	Date	Result
01	P1_2010_TH_VEN	Jun 22 2020	PASS
02	P1_2015_TH_VEN	Jun 22 2020	PASS
03	P1_2020_TH_VEN	Jun 22 2020	PASS
04	P1_2030_TH_VEN	Jun 22 2020	PASS
05	P1_2040_TH_VEN	Jun 22 2020	PASS
06	P1_2050_TH_VEN	Jun 22 2020	PASS

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 7 von of 17
Page 7 von of 17

4.1.1.3 EiReport Service

No.	Test Case Name	Date	Result
01	R1_3010_TH_VEN	Jun 22 2020	PASS
02	R1_3020_TH_VEN	Jun 22 2020	PASS
03	R1_3025_TH_VEN	Jun 22 2020	PASS
04	R1_3027_TH_VEN	Jun 22 2020	PASS
05	R1_3030_TH_VEN	Jun 22 2020	PASS
06	R1_3040_TH_VEN	Jun 22 2020	PASS
07	R1_3045_TH_VEN	Jun 22 2020	PASS
08	R1_3050_TH_VEN	N/A	N/A
09	R1_3060_TH_VEN	N/A	N/A
10	R1_3070_TH_VEN	Jun 22 2020	PASS
11	R1_3080_TH_VEN	N/A	N/A
12	R1_3090_TH_VEN	N/A	N/A
13	R1_3100_TH_VEN	N/A	N/A
14	R1_3120_TH_VEN	N/A	N/A
15	R1_3130_TH_VEN	Jun 22 2020	PASS
16	R1_3150_TH_VEN	Jun 22 2020	PASS
17	R1_3160_TH_VEN	Jun 22 2020	PASS
18	R1_3170_TH_VEN	N/A	N/A
19	R1_3180_TH_VEN	Jun 22 2020	PASS
20	R1_3190_TH_VEN	Jun 22 2020	PASS

4.1.1.4 EiEvent Service

No.	Test Case Name	Date	Result
01	E1_1010_TH_VEN	Jun 22 2020	PASS
02	E1_1020_TH_VEN	Jun 22 2020	PASS
03	E1_1025_TH_VEN	Jun 22 2020	PASS
04	E1_1027_TH_VEN	Jun 22 2020	PASS
05	E1_1030_TH_VEN	Jun 22 2020	PASS
06	E1_1040_TH_VEN	Jun 22 2020	PASS
07	E1_1050_TH_VEN	Jun 22 2020	PASS
08	E1_1055_TH_VEN	Jun 22 2020	PASS
09	E1_1060_TH_VEN	Jun 22 2020	PASS
10	E1_1065_TH_VEN	Jun 22 2020	PASS
11	E1_1070_TH_VEN	N/A	N/A
12	E1_1080_TH_VEN	Jun 22 2020	PASS
13	E1_1090_TH_VEN	N/A	N/A

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 8 von of 17
Page 8 von of 17

4.1.1.5 EiEvent Ported A Profile

No.	Test Case Name	Date	Result
01	A_E3_0420_TH_VEN	Jun 22 2020	PASS
02	A_E3_0430_TH_VEN	Jun 22 2020	PASS
03	A_E3_0432_TH_VEN	Jun 22 2020	PASS
04	A_E3_0435_TH_VEN	Jun 22 2020	PASS
05	A_E3_0440_TH_VEN	Jun 23 2020	PASS
06	A_E3_0450_TH_VEN	Jun 23 2020	PASS
07	A_E3_0452_TH_VEN	Jun 22 2020	PASS
08	A_E3_0454_TH_VEN	Jun 22 2020	PASS
09	A_E3_0468_TH_VEN	Jun 22 2020	PASS
10	A_E3_0470_TH_VEN	Jun 22 2020	PASS
11	A_E3_0474_TH_VEN	Jun 22 2020	PASS
12	A_E3_0480_TH_VEN	Jun 22 2020	PASS
13	A_E3_0484_TH_VEN	Jun 22 2020	PASS
14	A_E3_0490_TH_VEN	Jun 22 2020	PASS
15	A_E3_0492_TH_VEN	Jun 22 2020	PASS
16	A_E3_0494_TH_VEN	Jun 22 2020	PASS
17	A_E3_0496_TH_VEN	Jun 22 2020	PASS
18	A_E3_0498_TH_VEN	Jun 22 2020	PASS
19	A_E3_0500_TH_VEN	Jun 22 2020	PASS
20	A_E3_0510_TH_VEN	Jun 22 2020	PASS
21	A_E3_0525_TH_VEN	Jun 22 2020	PASS
22	A_E3_0527_TH_VEN	Jun 22 2020	PASS
23	A_E3_0655_TH_VEN	Jun 23 2020	PASS
24	A_E3_0657_TH_VEN	Jun 22 2020	PASS
25	A_E3_0680_TH_VEN	Jun 22 2020	PASS
26	A_E3_0685_TH_VEN	Jun 22 2020	PASS
27	A_E3_0710_TH_VEN	Jun 22 2020	PASS
28	A_E3_0720_TH_VEN	Jun 22 2020	PASS
29	A_E3_0730_TH_VEN	Jun 22 2020	PASS
30	A_E3_0750_TH_VEN	Jun 22 2020	PASS
31	A_E3_0780_TH_VEN	Jun 22 2020	PASS

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 9 von of 17
Page 9 von of 17

4.1.1.6 General Tests

No.	Test Case Name	Date	Result
01	G1_4005_TH_VEN	Jun 22 2020	PASS
02	G1_4007_TH_VEN	Jun 22 2020	PASS
03	G1_4010_TH_VEN	Jun 22 2020	PASS
04	G1_4011_TH_VEN	Jun 22 2020	PASS
05	G1_4012_TH_VEN	Jun 22 2020	PASS
06	G1_4015_TH_VEN	N/A	N/A
07	G1_4020_TH_VEN_1	Jun 22 2020	PASS
08	G1_4030_TH_VEN	Jun 22 2020	PASS

4.1.2 VTN Push Tests

4.1.2.1 EiRegisterParty Service

No.	Test Case Name	Date	Result
01	N0_5010_TH_VEN	Jun 23 2020	PASS
02	N0_5015_TH_VEN	Jun 23 2020	PASS
03	N0_5020_TH_VEN	Jun 23 2020	PASS
04	N0_5025_TH_VEN	Jun 23 2020	PASS
05	N0_5030_TH_VEN	Jun 23 2020	PASS
06	N0_5040_TH_VEN_1	Jun 23 2020	PASS
07	N0_5050_TH_VEN_1	Jun 23 2020	PASS
08	N0_5060_TH_VEN	Jun 23 2020	PASS
09	N0_5065_TH_VEN	Jun 23 2020	PASS
10	N0_5070_TH_VEN	Jun 23 2020	PASS
11	N0_5080_TH_VEN	Jun 23 2020	PASS

4.1.2.2 EiOpt Service

No.	Test Case Name	Date	Result
01	P0_7010_TH_VEN	Jun 23 2020	PASS
02	P0_7015_TH_VEN	Jun 23 2020	PASS
03	P0_7020_TH_VEN	Jun 23 2020	PASS
04	P0_7030_TH_VEN	Jun 23 2020	PASS
05	P0_7040_TH_VEN	Jun 23 2020	PASS
06	P0_7050_TH_VEN	Jun 23 2020	PASS

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 11 von of 17
Page 11 von of 17

4.1.2.3 EiReport Service

No.	Test Case Name	Date	Result
01	R0_8010_TH_VEN_1	Jun 23 2020	PASS
02	R0_8020_TH_VEN_1	Jun 23 2020	PASS
03	R0_8025_TH_VEN_1	Jun 23 2020	PASS
04	R0_8027_TH_VEN_1	Jun 23 2020	PASS
05	R0_8030_TH_VEN_1	Jun 23 2020	PASS
06	R0_8040_TH_VEN_1	Jun 23 2020	PASS
07	R0_8045_TH_VEN_1	Jun 23 2020	PASS
08	R0_8050_TH_VEN_1	N/A	N/A
09	R0_8060_TH_VEN_1	N/A	N/A
10	R0_8070_TH_VEN	Jun 23 2020	PASS
11	R0_8080_TH_VEN_1	N/A	N/A
12	R0_8090_TH_VEN_1	N/A	N/A
13	R0_8100_TH_VEN_1	N/A	N/A
14	R0_8120_TH_VEN_1	N/A	N/A
15	R0_8130_TH_VEN_1	Jun 23 2020	PASS
16	R0_8150_TH_VEN_1	Jun 23 2020	PASS
17	R0_8160_TH_VEN_1	Jun 23 2020	PASS
18	R0_8170_TH_VEN_1	N/A	N/A
19	R0_8180_TH_VEN_1	Jun 23 2020	PASS
20	R0_8190_TH_VEN_1	Jun 23 2020	PASS

4.1.2.4 EiEvent Service

No.	Test Case Name	Date	Result
01	E0_6010_TH_VEN_1	N/A	N/A
02	E0_6020_TH_VEN_1	Jun 23 2020	PASS
03	E0_6025_TH_VEN_1	Jun 23 2020	PASS
04	E0_6027_TH_VEN_1	Jun 23 2020	PASS
05	E0_6030_TH_VEN_1	Jun 23 2020	PASS
06	E0_6040_TH_VEN_1	Jun 23 2020	PASS
07	E0_6050_TH_VEN	Jun 23 2020	PASS
08	E0_6055_TH_VEN_1	Jun 23 2020	PASS
09	E0_6060_TH_VEN_1	Jun 23 2020	PASS
10	E0_6065_TH_VEN_1	Jun 23 2020	PASS
11	E0_6070_TH_VEN_1	N/A	N/A
12	E0_6080_TH_VEN_1	Jun 23 2020	PASS
13	E0_6090_TH_VEN_1	N/A	N/A

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 12 von of 17
Page 12 von of 17

4.1.2.5 EiEvent Ported A Profile

No.	Test Case Name	Date	Result
01	A_E2_0430_TH_VEN_1	Jun 23 2020	PASS
02	A_E2_0432_TH_VEN_1	Jun 23 2020	PASS
03	A_E2_0435_TH_VEN_1	Jun 23 2020	PASS
04	A_E2_0440_TH_VEN_1	Jun 23 2020	PASS
05	A_E2_0450_TH_VEN_1	Jun 23 2020	PASS
06	A_E2_0452_TH_VEN_1	Jun 23 2020	PASS
07	A_E2_0454_TH_VEN_1	Jun 23 2020	PASS
08	A_E2_0468_TH_VEN_1	Jun 23 2020	PASS
09	A_E2_0470_TH_VEN_1	Jun 23 2020	PASS
10	A_E2_0474_TH_VEN_1	Jun 23 2020	PASS
11	A_E2_0480_TH_VEN_1	Jun 23 2020	PASS
12	A_E2_0484_TH_VEN_1	Jun 23 2020	PASS
13	A_E2_0490_TH_VEN_1	Jun 23 2020	PASS
14	A_E2_0492_TH_VEN_1	Jun 23 2020	PASS
15	A_E2_0494_TH_VEN_1	Jun 23 2020	PASS
16	A_E2_0496_TH_VEN_1	Jun 23 2020	PASS
17	A_E2_0498_TH_VEN_1	Jun 23 2020	PASS
18	A_E2_0500_TH_VEN_1	Jun 23 2020	PASS
19	A_E2_0510_TH_VEN_1	Jun 23 2020	PASS
20	A_E2_0525_TH_VEN_1	Jun 23 2020	PASS
21	A_E2_0527_TH_VEN_1	Jun 23 2020	PASS
22	A_E2_0657_TH_VEN_1	Jun 23 2020	PASS
23	A_E2_0680_TH_VEN_1	Jun 23 2020	PASS
24	A_E2_0685_TH_VEN_1	Jun 23 2020	PASS
25	A_E2_0710_TH_VEN_1	Jun 23 2020	PASS
26	A_E2_0720_TH_VEN_1	Jun 23 2020	PASS
27	A_E2_0730_TH_VEN_1	Jun 23 2020	PASS
28	A_E2_0750_TH_VEN_1	Jun 23 2020	PASS
29	A_E2_0780_TH_VEN_1	Jun 23 2020	PASS

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 13 von of 17
Page 13 von of 17

4.1.2.6 General Tests

No.	Test Case Name	Date	Result
01	G0_9005_TH_VEN_1	Jun 24 2020	PASS
02	G0_9010_TH_VEN_1	Jun 24 2020	PASS
03	G0_9020_TH_VEN_1	Jun 22 2020	PASS
04	G0_9030_TH_VEN_1	Jun 24 2020	PASS

4.1.2.7 XMPP Tests

No.	Test Case Name	Date	Result
01	N0_5020_TH_VEN	Jun 22 2020	PASS
02	N0_5030_TH_VEN	Jun 22 2020	PASS
03	P0_7040_TH_VEN	Jun 22 2020	PASS
04	R0_8030_TH_VEN_1	Jun 22 2020	PASS
05	E0_6030_TH_VEN_1	Jun 22 2020	PASS
06	A_E2_0525_TH_VEN_1	Jun 22 2020	PASS
07	G0_9005_TH_VEN_1	Jun 22 2020	PASS
08	G0_9010_TH_VEN_1	Jun 22 2020	PASS

4.2 Profile 2.0a

4.2.1 VTN Pull Tests

4.2.1.1 Application Layer Test Cases

No.	Test Case Name	Date	Result
01	E3_0420_TH_VEN	Jun 23 2020	PASS
02	E3_0430_TH_VEN	Jun 23 2020	PASS
03	E3_0432_TH_VEN	Jun 23 2020	PASS
04	E3_0435_TH_VEN	Jun 23 2020	PASS
05	E3_0440_TH_VEN	Jun 23 2020	PASS
06	E3_0450_TH_VEN	Jun 23 2020	PASS
07	E3_0452_TH_VEN	Jun 23 2020	PASS
08	E3_0454_TH_VEN	Jun 23 2020	PASS
09	E3_0468_TH_VEN	Jun 23 2020	PASS
10	E3_0470_TH_VEN	Jun 23 2020	PASS
11	E3_0474_TH_VEN	Jun 23 2020	PASS
12	E3_0480_TH_VEN	Jun 23 2020	PASS
13	E3_0484_TH_VEN	Jun 23 2020	PASS
14	E3_0490_TH_VEN	Jun 23 2020	PASS
15	E3_0492_TH_VEN	Jun 23 2020	PASS
16	E3_0494_TH_VEN	Jun 23 2020	PASS
17	E3_0496_TH_VEN	Jun 23 2020	PASS
18	E3_0498_TH_VEN	Jun 23 2020	PASS
19	E3_0500_TH_VEN	Jun 23 2020	PASS
20	E3_0510_TH_VEN	Jun 23 2020	PASS
21	E3_0525_TH_VEN	Jun 23 2020	PASS
22	E3_0527_TH_VEN	Jun 23 2020	PASS
23	E3_0655_TH_VEN	Jun 23 2020	PASS
24	E3_0657_TH_VEN	Jun 23 2020	PASS
25	E3_0660_TH_VEN	Jun 23 2020	PASS
26	E3_0680_TH_VEN	Jun 23 2020	PASS
27	E3_0685_TH_VEN	Jun 23 2020	PASS
28	E3_0710_TH_VEN	Jun 23 2020	PASS
29	E3_0720_TH_VEN	Jun 23 2020	PASS
30	E3_0730_TH_VEN	Jun 23 2020	PASS
31	E3_0750_TH_VEN	Jun 23 2020	PASS
32	E3_0780_TH_VEN	Jun 23 2020	PASS

4.2.1.2 Security Test Cases

No.	Test Case Name	Date	Result
01	S3_1600_TH_VEN	Jun 23 2020	PASS
02	S3_1605_TH_VEN	Jun 23 2020	PASS

4.2.2 VTN Push Tests

4.2.2.1 Application Layer Test Cases

No.	Test Case Name	Date	Result
01	E2_0430_TH_VEN	Jun 24 2020	PASS
02	E2_0432_TH_VEN	Jun 24 2020	PASS
03	E2_0435_TH_VEN	Jun 24 2020	PASS
04	E2_0440_TH_VEN	Jun 24 2020	PASS
05	E2_0450_TH_VEN	Jun 24 2020	PASS
06	E2_0452_TH_VEN	Jun 24 2020	PASS
07	E2_0454_TH_VEN	Jun 24 2020	PASS
08	E2_0468_TH_VEN	Jun 24 2020	PASS
09	E2_0470_TH_VEN	Jun 24 2020	PASS
10	E2_0474_TH_VEN	Jun 24 2020	PASS
11	E2_0480_TH_VEN	Jun 24 2020	PASS
12	E2_0484_TH_VEN	Jun 24 2020	PASS
13	E2_0490_TH_VEN	Jun 24 2020	PASS
14	E2_0492_TH_VEN	Jun 24 2020	PASS
15	E2_0494_TH_VEN	Jun 24 2020	PASS
16	E2_0496_TH_VEN	Jun 24 2020	PASS
17	E2_0498_TH_VEN	Jun 24 2020	PASS
18	E2_0500_TH_VEN	Jun 24 2020	PASS
19	E2_0510_TH_VEN	Jun 24 2020	PASS
20	E2_0525_TH_VEN	Jun 24 2020	PASS
21	E2_0527_TH_VEN	Jun 24 2020	PASS
22	E2_0657_TH_VEN	Jun 24 2020	PASS
23	E2_0670_TH_VEN	Jun 24 2020	PASS
24	E2_0680_TH_VEN	Jun 24 2020	PASS
25	E2_0685_TH_VEN	Jun 24 2020	PASS
26	E2_0710_TH_VEN	Jun 24 2020	PASS
27	E2_0720_TH_VEN	Jun 24 2020	PASS
28	E2_0730_TH_VEN	Jun 24 2020	PASS
29	E2_0750_TH_VEN	Jun 24 2020	PASS
30	E2_0780_TH_VEN	Jun 24 2020	PASS

4.2.2.2 Security Test Cases

No.	Test Case Name	Date	Result
01	S2_1500_TH_VEN	Jun 23 2020	PASS

4.2.3 Transport Tests

No.	Test Case Name	Date	Result
01	T9_1200	Jun 24 2020	PASS

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 16 von of 17
Page 16 von of 17

5 Remarks and References

Due to a bug in the test harness, the Test case A_E2_0525_TH_VEN_1 / E2_0525_TH_VEN are not executed normally. The correct operation was confirmed by using the corrected patch version.

<http://techsupport.qualitylogic.com/>

Ticket #314733

Log files for the executed test cases are provided in the electronic format.

List of all executed tests with links to the log files is located in the "logfile.html" which could be opened in any web-browser.

Prüfbericht-Nr.:
Test Report No.:

60362718 001

Auftrags-Nr.:
Order No.: 150224608

Seite 17 von of 17
Page 17 von of 17

6 Photos

2020-06-23 13:09:36,685 INFO conf.BootStrap VTN version : 2.0.0

Photo 1: FW Version

Index > **VTN GUI** Home Registration **Event** Report OptStatus Payload Editor 表示設定クリア

Event List DB Table & Column 表示項目選択 ▼

Event ID	Status	Signals	Start	End	Modification Number	Ven ID	Profile
Event250614_052007_404_0	Pending	1	2020-06-23 17:46:58	2020-06-23 17:51:58	0	TH_VEN	2.0b

Signals DB Table & Column 表示項目選択 ▼

event_id	name	signalid	type	AC	Description	Hertz	Name	SI scale code	Units	Voltage
76	ELECTRICITY_PRICE	SIG_02	PRICE	false	currencyPerKWh	0	(http://openadr.org/oadr-2.0b/2012/07/currencyPerKWh	none	USD	0

Intervals DB Table & Column 表示項目選択 ▼

Duration millis	Level	Start	UID
300000	3.14	2020-06-23 17:46:58	0

Baselines DB Table & Column 表示項目選択 ▼

baselineid	duration	event_id	name	start_date	AC	Description	Hertz	Name	SI scale code	Units	Voltage
------------	----------	----------	------	------------	----	-------------	-------	------	---------------	-------	---------

Baseline Intervals DB Table & Column 表示項目選択 ▼

baseline_id	duration	float_value	start	uid
-------------	----------	-------------	-------	-----

Target List DB Table & Column 表示項目選択 ▼

event_id	Resource ID	Party ID	Ven ID	Service Point
----------	-------------	----------	--------	---------------

Ven Status DB Table & Column 表示項目選択 ▼

VEN ID	Event ID	Opt Status	Updated	Group ID	Group Name	Party ID	Resource - Time	Resource ID	End Device
TH_VEN	Event250614_052007_404_0	DISTRIBUTE_SENT	2020-06-23 17:37:00.259	null	null	null		null	null

Photo 2: System screen capture